

Structural Certification: Producer Statement
Hy90 used as lintels in residential construction

I, Ross Davison, being registered under the provisions of the Engineer's Registration Amendment Act 1944 and currently holding an Annual Practising Certificate hereby certify that a 63mm thick Hyspan lintel derived from the designIT software can be substituted by a Hy90 lintel of the same depth.

Where installed in accordance with:

- the specifications, details and limitations in the Hy90 Lintels for Residential Construction brochure, and
- the minimum bearing length derived from the designIT software, the Hy90 lintel will comply with the requirements of the New Zealand Building Code.



Ross Davison
BE (Civil), MIPENZ
Registration number 9133
June 2003